



IPES-IR3 Flame Detector Operating Manual

820-0003



ESP SAFETY INC

Technology of the Future...Protection for today

IPES-IR3 Flame Detector Operating Manual 820-0003

ESP Safety, Inc.
555 North First Street
San Jose, CA 95112 USA
408-886-9746

October 2014

Revision History: 820-0003

Date	Revision	Description	Approved
3/14/13	02	Addition; Appendix C Warranty & Return Policy	Burgos
3/25/13	03	Reformat	Burgos
2/28/14	04	Updated Functional Test Procedure	Burgos
10/31/14	A	Update FM references; change PN from 80010-001; steel enclosure only	ECO 141103

Table of Contents

1.0 Introduction	1
Our Mission.....	1
ESP Safety, Inc. Contact Information	1
2.0 Description	2
Application.....	2
Specifications	2
3.0 Safety Considerations	3
Guidelines	4
Explosion Protection Means	4
4.0 FM Compliance	5
IPES-IR3	5
5.0 Performance Characteristics	7
Appearance.....	7
Response Time.....	7
Generation of Alarm Signals	7
Elimination of False Alarms.....	8
Serviceability.....	8
LED	8
Optical Integrity	8
Analog Signal.....	10
Digital Signal	10
Relay Dry Contact Signal	10
Operating Modes	10
6.0 Installation	11
Component Parts and Delivery Set	11
Visual Examination.....	11
Pre-Installation Steps.....	11
Installation	11
General Wiring Requirements	12
Completing the Installation.....	15
7.0 Startup and Operation	17
Fire Detection Test.....	19
Dust/ Obstruction Fault Test.....	20
8.0 Troubleshooting	21
Troubleshooting Table	21

9.0 Maintenance	22
Maintenance Activities	22
Daily Maintenance	22
Every Six Months.....	22
Automatic Testing.....	23
10.0 Transportation and Storage	24
Transportation	24
Storage.....	24
11.0 Warranties	24
Expected Service Life of Unit	24
12.0 Repair and Return	25
Field Repair	25
Return Material Authorization (RMA) Number.....	25
13.0 Parts Ordering Information	25
14.0 Certifications	26
Appendix A: IPES-IR3 Explosion Protection Means	28
Appendix B: IPES-IR3 Installation	29
Appendix C: IPES Digital Communications Protocol	31



It is important that this entire manual be thoroughly read and understood prior to installing or operating the IPES-IR3. Any deviation from the recommendations in this manual may impair system performance and compromise safety.

1.0 Introduction

Introduction

The IPES-IR3 flame detector's advanced microprocessor based technology ensures rapid flame recognition and alarm signaling. In addition, the IPES-IR3's selective, multiple spectrum technology virtually eliminates false alarms from a variety of sources including:

- Direct or indirect sunlight
- Arc welder flash, resistive heaters
- Fluorescent, halogen
- Incandescent light
- Nuclear radiation

The IPES-IR3 generates an alarm signal only when detection from three different IR wavelengths agree that a flame or fire is present in the field of view. Upon confirmation of flame or fire, the IPES-IR3 triggers alarm relays and provides alarm signals via RS-485 Modbus and industry standard +4 to 20mA current loop to the users' receiving devices and alarm systems.

For ease of operation status and alarm condition the IPES-IR3 provides an easily visible high illumination Tri State LED that follows an Industry Standard protocol:

- *Green for normal operation*
- *Yellow for fault condition*
- *Red for alarm Conditions*

The IPES-IR3 provides superior false alarm processing making it the detector of choice. Alarms occur instantly after our proprietary False-Positive Algorithm determines possible alarm states. This makes IPES-IR3 the industry standard for several industrial applications:

Our Mission

ESP Safety, Inc.'s mission is to provide complete turn-key protection solutions beginning with the design stage, through system installation and commissioning, and on-going field service in hazardous environments. Our line of industry-leading products, services, and systems benefits society, saves lives, and preserves capital resources.

ESP Safety, Inc. Contact Information

Telephone: 408-886-9746

FAX: 408-886-9757

Address: 555 North First Street, San Jose, CA 95112 USA

2.0 Description

Application

The IPES-IR3 design and explosion-proof ratings make it an excellent choice for indoor and outdoor applications, including:

- Drilling and production
- Automated and manned ocean based platforms.
- Fuel loading and transfer facilities
- Refineries
- Bulk terminals
- Tank farms and storage facilities
- LNG/LPG processing and storage
- Compressor stations
- Pipelines and pump stations
- Petrochemical processing facilities
- Fertilizer production
- Paint production
- Power Plants- Nuclear, Coal, Oil, Natural Gas, Solar Process, MHD
- Shipping Tankers, Freighters. Virtually any vessels that may have a potential fire hazard.
- Laboratory and Plasma Study/Process
- Transportation facilities, Airports, Subways, Aircraft hangers
- Oil and Gas Boilers
- Stage and entertainment special effects

Specifications

The IPES-IR3 meets industry certifications and requirements for Hazardous Locations.

Detection Type: Optical

Detection Method: Multiple Spectrum Infrared Radiation Source

Spectral Range: Three points in a range of 4.0 to 5.0 μm

Detection Process Time:

4.5 to 7 Seconds
(Complies with FM Standard 3260)
Refer to Section 4.0

Detection Distance: Minimum 41ft (12.5m) to 82ft (25m) depending on detected fuel. Refer to Section 4.0

Detection Cone of Vision: Up to 90° (45° Left/Right of center)

Sensitivity: User Selectable for distance and False/Positive process time

Power requirements- 24VDC nominal (18-32VDC range)

Power Consumption:

3 VA (3 Watt) Max

Outputs:

- Industry Standard +4 to 20mA
 - 1 Alarm Relays (SPDT/Form-C latching)
 - 1 Fault condition (NO/Form-A)
- *All Relays Contact Rating 1 Amp@125VAC/30VDC
- Digital RS-485 Modbus

Cable Distance: 6200ft (1900m) 18 AWG

Ingress Protection: IP66

Vibration: Meets FM 3260: 2000

Impact Resistance: 1.9 Joules

Test Method: IPES Test Lamp

RFI-resistant to interference by EMI and RFI: EMC Directive compliant with CE mark. Not susceptible to keying 5 watt walkie-talkie at distances greater than 1 foot.

Optical Integrity: IPES-IR3 performs an automatic calibrated performance test once per minute to verify complete detector operation capabilities.

Operating Temperature: -40°F to +185°F (-40°C to 85°C)

Storage Temperature: -76°F to +185°F (-60°C to 85°C)

Humidity Range: 0 to 95% relative humidity
(can withstand 100% condensing humidity for short periods of time)

Conduit Entry: ¾" NPT

Enclosure Material: Stainless Steel Grade 316

Weight: Stainless Steel 11lbs (5.0kg)

Included Equipment:

IPES-IR3 Fire Detector

Adjustable Mounting Bracket

Magnetic Test Collar

Optional Equipment

- Sun Shade Hood

IPES-IR3 Configuration and Monitoring Software

3.0 Safety Considerations



Before installing and operating the IPES-IR3, be sure to read this entire manual. Failure to follow these guidelines could result in impaired product performance and safety hazards.

Guidelines

For maximum safety:

- Only persons who have thoroughly read and understood this manual, are trained in safety techniques, and have electric-safety certificates are permitted to install and operate the IPES-IR3.
- Never operate the IPES-IR3 if the casing is damaged.
- Do not open, separate or disassemble the IPES-IR3 when energized.
- Refer to the Appendices and diagrams in this manual to ensure that the wiring is in compliance with local ordinances and the NEC.
- Perform regular testing and maintenance as outlined in the Maintenance section.
- Ensure that fire-alarm and fire-extinguishing systems and controls are switched off before any testing or maintenance to avoid unwanted operation of alarms and fire-extinguishing equipment.

Also see the individual sections in this manual for relevant specific safety guidelines.

**Explosion
Protection Means**

The table below describes design features that protect the IPES-IR3 against explosions:

Feature	Protection Means
<i>Enclosure of Current Carrying Parts</i>	The casing includes spigot joints with controlled gaps to meet explosion-proof requirements for installation in Class I, Division I, Group B, C and D, and T4 locations.
<i>Case Mechanical Strength</i>	The high mechanical strength of the case is able to withstand high explosive pressures without rupture or failures of mechanical parts. The case design is in accordance with FM 3600 and FM 3615.
<i>Manufacturing Control Of Casing</i>	Refer to Appendix B for manufacturing details. Important parameters include: <ul style="list-style-type: none"> • Maximum width and minimum length of spigot joints • Surface roughness of the joined parts • The number of complete intact threads at the conduit entry point
<i>Ignition Temperature</i>	The ignition temperature of the surrounding environment is limited by the outside surface temperature of the housing, which does not exceed 275°F (135°C).
<i>Securing of Bolts, Joints and Grounding</i>	Spring washers, lock washers, and lock nuts maintain the integrity of the bolted connections by preventing loosening of the bolts.
<i>Joined Parts Protection</i>	Anti-seize lubricant is applied on the critical joints as described on Appendix A.
<i>Casing Ingress Protection</i>	The design of the casing is protection class IP 66 in accordance with IEC 60529-004.
<i>Sealing Cables at Conduit Entry</i>	Use approved hazardous location sealed conduit fittings. For outdoor installations, ensure sealing meets IP66 requirements.

4.0 FM Compliance

IPES-IR3

Meets FM (US and Canada) certifications and requirements for Hazardous Location classification: Class I, Division I, Group B, C and D and T4 Case design accords with FM 3600 and FM 3615. Ta = -40°C to +85°C (-40°F to +185°F) IP66

Standards

TITLE	AUTHOR-NUMBER	DATE
National Fire Alarm Code	ANSI/NFPA 72	2002
Radiant Energy-Sensing Fire Detectors for Automatic Fire Alarm Signaling	ANSI/FM – 3260	2004
Radiant Energy-Sensing Fire Detectors for Automatic Fire Alarm Signaling	FM Approvals - 3260	2000
Electrical Equipment For Use In Hazardous (Classified) Locations – General Requirements	FM Approvals – 3600	1998
Explosion proof Electrical Equipment – General Requirements	FM Approvals – 3615	2006
Flame Detectors	ULC/ORD - C386	1990
Standard for Smoke Detectors for Fire Alarm Systems	CAN/ULC - S529	2002
Threaded Conduit Entries	CSA C22.2 No. 0.5 (Reaffirmed)	1982 (1999)
Explosion-Proof Enclosures for Use in Class I Hazardous Locations	CSA C22.2 No. 30 (Reaffirmed)	1986 (2003)
Degrees of Protection Provided by Enclosures (IP Code)	ANSI/IEC 60529 CSA-C22.2 No. 60529	2004 2005
Explosive Atmospheres, General Requirements	ANSI/ISA 60079-0	2009
Explosive Atmospheres, Equipment protection by flameproof “d” enclosures	ANSI/ISA 60079-1	2009

**Flame Response
Sensitivity**

When an IPES-IR3 detector is exposed to a series of test fires along the center line of the sensor as described in the table below, the alarm response of the IPES-IR3 is below the 30-second response time required under FM Standard 3260.

Fuel	Distance	Fire Size	Average Time
n-Heptane	211 ft. (64 m.)	1 ft. x 1 ft. (32.5 cm.) pan	9 sec.
Denatured ethyl alcohol (85.4%)	151 ft. (46 m.)	1 ft. x 1 ft. (32.5 cm.)	11 sec.
JP4	206 ft. (63 m.)	2 ft. x 2 ft. (60 cm.) pan	10 sec.


False Stimuli Exposure

When the IPES-IR3 is exposed to the fires specified above, and are in the presence of the following false stimuli sources – modulated at approximately 1.5 Hz, and un-modulated – no false alarm activation or instability occurs at the minimum distances listed below.

Source	Distance
1.5 kW Heater	36 inches (0.9 m)
Arc welder, 200A, 3/16" – 7018 electrode	9.0 feet (3.7 m)
Fluorescent, (2) 20W (6000 Lux)	0 inches (0 m)
Halogen, 500W	36 inches (0.9 m)
Incandescent, 100W (2000 Lux)	12 inches (0.3 m)
Direct sunlight	Detectors not affected by frequency range of visible light
Indirect sunlight	Detectors not affected by frequency range of visible light


Field of View

The IPES-IR3 has a 90° cone of vision (horizontal) with the highest sensitivity lying along the central axis



X= Distance in Ft Y= Angle of Vision
Refer to Appendix XX for testing method

5.0 Performance Characteristics



Shown: IPES IR3 w Type 316 SS housing.

Figure 5-1: IPES-IR3 Components

Appearance

The IPES-IR3 consists of an explosion-proof casing with sensors to detect electromagnetic radiation from flames at three points within a spectral window of 4.0 to 5.0 μ m. Detection is performed using Infrared Sensors that capture heat and radiating gas signatures emitted by fire. Significantly, the IPES-IR3 can detect fires fueled by hydrocarbon-based liquids and gases that may not be visible to the human eye.

The basic technology is well tested and used for many devices designed for human interaction. These include night vision equipment, FLIR navigation assist, and Spectral Telescopes used in astronomy.

The IPES-IR3 uses microprocessors with proprietary algorithms that transform the detected signal into industry standard analog and digital communication signals, alarms indicators.

Response Time

The IPES-IR3 response time detecting radiation emitted by test sources of n-Heptane combustion in a 12" x 12" (0.3m by 0.3m) pan, and ethyl alcohol combustion in a 12" x 12" (0.3m by 0.3m) pan, at a distance of 150 feet (46 meters) does not exceed 30 seconds.

The sensitivity and response time can be varied in order to reduce unwanted "noise" when the IPES-IR3 identifies a fire, or the distance to the probable place of fire is short ("near/far" and "slow/fast" modes).

Generation of Alarm Signals

The IPES-IR3 takes the following parameters into consideration when generating an alarm signal:

- Magnitude of signals from different optical channels
- Ratios between the signal amplitudes of different channels
- Signal modulation frequency
- Phase relationships among the channels

Elimination of False Alarms

False alarms from detectors used for industrial applications can cost productivity in down time. This is especially noted for automated systems and processes.

Conversely, failure to generate an alarm can have catastrophic results.

The combination of microprocessor, algorithms, multiple sensors and wavelength range settings makes the IPES-IR3 an excellent choice for elimination of false positive indicators caused by non-flame sources of radiation such as artificial lighting, direct and indirect sunlight, lightning, electrical arcs, radiation (nuclear), arc welding and metal grinding.

An Alarm condition will normally override a Fault condition unless a loss of operating power impairs the detector's ability to generate or maintain an alarm. The IPES-IR3 reports both Fault and Alarm conditions exclusive of each other. This means both a Fire and Fault can be reported at the same time if they occur simultaneously.

Serviceability

The IPES-IR3 remains serviceable in non-heated rooms or under sheds at temperatures from –40°F to +185°F (–40° to +85°C).

LED

Normal, Fire and Fault conditions are indicated by status LEDs located on the cover. Refer to Table 5-1: Determining LED Conditions.

Optical Integrity

To maintain reliability of the IPES-IR3, the optical devices are automatically self-tested for radiation transmission every 25 to 45 minutes. This routine test does not require the use of a test lamp. This test determines whether any dust or other contamination has formed on the detecting windows which would scatter the infrared radiation.




Figure 5-2: IR Detectors and LED Indicators

Table 5-1: Determining LED Conditions

After completing all installation steps, refer to the illustration and LED indicator table below to determine LED conditions.

State	IPES-IR3 status	Fire Relay State	Fault Relay Status	Output signal, am	LED Status Condition
		Normally open when energized	Normally closed when energized		
1	No power supply voltage	Open	Open	0mA	Off
2	After switching on during 45 sec.	Open	Open	2mA	Continuous green LED light for the first 10 sec. and then the green LED will begin flashing.
3	Fault or optical interference (dust)	Open	Open	2mA	Alternate flashing of the yellow and green LED lights.
4	Normal (no faults or fires during operation)	Open	Closed	4mA	Continuous lighting of the green LED light.
5	Fire	Closed	Closed	18mA	Continuous lighting of the red LED light.
6	Fire & Fault	Closed	Open	8mA	Alternate flashing of the yellow and green LED light.
7	Test mode (magnetic collar is on)	Open	Open	2mA	Magnetic collar is on. fire relay is blocked.

Analog Signal

Analog signal (4-20 mA)	
Signal level	Detector State
(±0.1) mA	Circuit opening
(2 ± 0.1) mA	Fault
(4 ± 0.1) mA	Normal
(18 ± 0.1) mA	Fire
(2 ± 0.1) mA	Test

Digital Signal

Informational digital signals are standard RS-485 communication with Modbus:

- Hardware self-test Fault
- Optical interference Fault
- Fire detected

(The digital channel protocol Modbus RTU is described in Appendix B.)

Relay Dry Contact Signal

Relay dry contact signal:

- Operation of the normally open Fire relay dry contacts *
 - FIRE relay – two-directional single-pole contact, which allows the state to be changed at the output to normally closed or normally open by using the ESP Commander program. The contact relay is rated for currents ranging from 10 mA to 5 A at DC voltage of 30 V.

The output signal “Fire” can be cleared after eliminating the source of the alarm signal.

* A normally closed condition of the Fire relay contacts does not comply with the requirements of NFPA 72 or ULC/ORD – C386 and is not approved by FM approvals.

- Operation of the normally open Fault relay dry contacts
 - FAULT relay – single-direction pole contact which is normally open. The relay is designed to handle currents of 10 mA to 5 A at DC voltage of 30 V.

Refer to Table 5-1: Determining LED Conditions above.

Operating Modes**Possible detector configurations using ESP Commander**

The IPES-IR3 has the following detector operating modes:

- “Near/far” and “slow/fast” modes – To provide maximum sensitivity.
- “Latching/non-latching mode” – To select either latching or non-latching functionality of the fire relay, which provides latching alarm state for the fire-alarm relay in compliance with NFPA 72 and ULC/ORD – C386.

The manufacturer’s default settings correspond to far and fast. To change the manufacturer’s settings connect the flame detector to the computer and use the ESP Commander program.

6.0 Installation

Component Parts and Delivery Set

The IPES-IR3 detector component parts and delivery set consists of the following:

- One IPES-IR3 Detector with one mounting base.
- One Operating Manual
- Accessory Kit (bolts, nuts, washers, etc.). Refer to Appendix B, Drawing 80031-001, for further details.
- Optional magnetic collar (delivered only by special request).

Compare the contents of the set to the packing list to be sure all items were received. If any items are missing, contact ESP Safety Inc.

Visual Examination

Before installing the IPES-IR3, examine the detector to be sure that:

- The nameplates and warning labels are in place.
- The external surfaces of the elements and joined surfaces of the casing are free of dents or damage. (Refer to Appendix B, Drawing 80031-001.)
- The tamper-proof screw is intact on the front cover (See Appendix B, Drawing 80031-001.)

Pre-Installation Steps

Make sure all removable parts are joined to the casing as tightly as possible.



Warning: Do not open, separate or disassemble casing when energized! Separating the casing can result in serious damage to the detector which could go undetected, resulting in failure to detect fires.

Installation

Positioning the Detector

1. Position the detector to provide an unobstructed view of the area to be protected. The detector's 90° viewing angle is most sensitive along the central axis; therefore, position the central axis so that it has the best unobstructed view of the place of probable fire. Use line of sight or laser level for more precise targeting.
2. Identify all high risk fire sources, to determine the number of detectors needed for adequate coverage.
3. Locate the detector(s) for ease of cleaning and servicing. Ensure that probable fire sources are within the detector(s) field of view and detection range.
4. When installing multiple detectors in the same area, be aware of overlapping fields of view and detector hierarchy. Overlapping fields of view can be used to provide additional protection against false positives or false negatives, depending on the control system logic connected to the detectors.

Note: To mitigate false positives, position the detector so that its field of view does not cover any areas outside the hazardous area.

5. Mount the detector on a rigid surface which minimizes vibrations. Use the mounting hardware provided along with the rubber bushings to further isolate the detector from vibrations (see Appendix B, Drawing 80031-001, Sheet 1).

Note: ESP Safety Inc. recommends bolting the mounting base plate to the mounting surface. If bolting is not possible, the mounting plate can be welded to the mounting surface if it is a similar metal (either 316 Stainless Steel or 6061 aluminum). Before welding, be sure to remove the detector from the base plate before attempting any weld operation.

Moisture Damage Protection

- It is the responsibility of the installer to take proper precautions during installation to protect the electrical connections and components from moisture.
- Anti-seize lubricant is provided for easy assembly and corrosion protection of the joints between the enclosure/cover and enclosure/base. After disassembly, wipe these surfaces clean with a soft cotton or wool cloth and then re-apply a thin layer of lubricant prior to assembly. See Appendix B (Drawing 80031-001, Sheet 1).
- If installing wiring cable in conduit, do not use conduit for wiring to other equipment.
- Care should be taken to not install the detector where heavy condensate, rain, or fog can cover the lens and reduce the sensitivity of the detector.

General Wiring Requirements



Caution: All cable/conduit entries must be sealed with an appropriate and certified sealing plug and cable gland. The use of industrial grade, armored field cable is recommended.

Cabling Guidelines

If installing connection cables in an explosion proof conduit, do not use the same conduit to carry wiring for any other purpose or equipment.

Minimum 14 AWG (2.08 mm²) shielded cable conductors are required for optimal performance. The gauge of the wire used determines the maximum distance between the 24VDC power sources.

When using Modbus, power and signal must be separate shielded twisted pair conductors

24VDC Requirements

The IPES-IR3 detector has a maximum power draw of 3VA/Watt in an active alarm state with all relays and optics heater active. (Fault, Alarm1) Select a power supply with adequate capability for the calculated load. Ensure that the 24VDC (+/-8VDC) power positive and common connections are from the same source



Warning: System ground must be provided at the point of origination for 24VDC. Failure to do this may result in loss of range and/or signal integrity.

Avoid low frequency, high voltage, and non-signaling conductors to prevent potential EMI problems.



Earth Grounding

The enclosure of the IPES-IR3 must be earthed/grounded for electrical safety and to limit the effects of radio frequency interference. An earth/ground point is provided on the outside of the IPES-IR3 Explosion Proof enclosure.

Use 14 AWG copper (Stranded, or Solid), wire.

Loosen the nut sufficiently to enable wrapping of the wire or wire terminated with a crimped lug around the thread in a "U" shape. Raise the flat and lock washers and position the wire between the 2 flat washers and ground base.

*Note: Earth and System Grounds are separated to prevent ground loop potential plus maintain signal and current output integrity

Power Cable Conductor Size affects Cable Length


The IPES-IR3 detector must receive a nominal voltage of 24 VDC (+/- 8VDC) to operate properly.

Wire size requirements are dependent upon power supply voltage and wire length.

There are several possible methods to electrically connect an IPES-IR3 that are determined by each user's application.

These can run from a single IPES-IR3 running on 24VDC that is operating as an isolated device and is connected directly to a warning system of alarms and/or lights to a network of devices that are connected in series that can provide any mix of RS-485 Modbus, +4 to 20 am, and relays to separate devices.

22 AWG 0.326mm ²)	40.5Ω	750	2460
20 AWG 0.518mm ²)	40.8	1200	3936
18 AWG 0.823mm ²)	40.7Ω	1900	6232
16 AWG (1.31mm ²)	40.2Ω	3000	9840

**Table 6-1: Arrangement of Electrical Connections**

Terminal block type A	Pin	Function
X1	+24V	24VDC from system power source (External User Provided)
	GND (0V)	System Ground from system power source (External User Provided)
X2	+4/20	Industry Standard +4-20mA current loop output
	RS485A	RS-485 MODBUS
	RS485B	RS-485 MODBUS
X3	R_WORK R_WORK	Fault / Obstruction Relay Normally Closed (NC Type B) When Energized
X1	+24V	Output to next device if required
	GND (0V)	Output to next device if required
X2	+4/20	Industry Standard +4-20mA current loop output
	RS485A	Output to next device if required
	RS485B	Output to next device if required
X3	R_FIRE R_FIRE	Alarm Relay Normally Open (NO Type A) When Energized

Arrangement of Electrical Connections

Arrange the electrical connections as described in Table 6-1, Table 6-2 and Figure 6-3 below.

To connect the IPES-IR3 to external devices, use armored control cables 4 x 1.5, which are used in all classes of explosive zones including indoor and outdoor sites, channels, tunnels, ground (trenches) with corrosive medium, and in zones containing roaming currents.

Setting the Modbus Address and Baud Rate

To ensure proper communications, a unique address must be assigned to each device, as duplicate addresses are not automatically detected. Modules with duplicate addresses will report with the same address, confusing latest updates. Record all addresses and device types after completing the installation.

Refer to Appendix B for setting the Modbus address and baud rate.


When using an RS-485 bus connection, it is advisable to connect the IPES-IR3 to the bus via the terminal box. To connect the detector to the terminal box, use a cable not longer than 1.64 feet (0.5 m). The cable characteristics should meet the requirement of the cable entries mounted on the IPES-IR3 casing and those of the terminal box.

**Completing the
Installation**

For the following, refer to the illustrations in Appendix B (Drawing 80025-001, Sheets 1 and 2).

1. Unscrew the M5 Socket Head Cap screws from the base. Remove the detector from the base.
2. Detach NPT conduit bushing from base.
3. Install the base on a suitable work platform and secure using the 4 mounting screws, washers, nuts, and rubber grommets.
4. Run the power, control, and ground wires from the conduit into the conduit bushing and connect to the wiring terminals in the base. Follow Figure 6-2, Arrangement and Functions of Mounting Connection Terminals, for details.
5. Tighten the conduit bushing to 4-1/2 +- 1 turns of engagement. **Seal** the conduit entry with an approved hazardous location conduit sealant.
6. Run the earth ground wire to the external ground stud on the base.
7. After completing all wiring, refer to Table 6-1 to verify the functionality of the front cover LEDs.
8. Inspect base and re-apply a thin film of anti-seize compound if required; re-install the detector on the base and evenly tighten the M5 screws to 40 in-lbs.
9. Upon completing the installation, check the resistance of the earth ground lug to ground which should not exceed 1 ohm.
10. Arrange the power-supply system so that the power-supply voltage across the device terminals ranges from 18 to 32 V (taking into account the IPES-IR3 consumption).

IPES-IR3 3 Wire +4 to 20 mA Current Loop Wiring Diagram



When using the current loop method of connection the circuit is a point-to-point connection between a single IPES-IR3 and a threshold detection device. In most cases the threshold device will provide the 24VDC power and will operate in a closed loop. Refer to Appendix C for interpretation of +4 to 20ma indications.

If 24VDC is from a common source, use of a connection bus-block is recommended to provide connect/disconnect capability without disruption to any other devices using the same power source.

Figure 6-3: IPES-IR3 Connection to Analog +4 to 20 mA Current Loop

Connection to Digital RS-485 Circuit




Figure 6-4: IPES-IR3 Connection to Digital RS-485 Circuit

7.0 Startup and Operation

Installation Review Prior to Startup

Once the mounting, cabling, and alarm relay installation has been completed, the IPES IR3 is ready to begin the power-on sequence.

Before applying power to the system for the first time, review the steps below:

- Verify that the IPES IR3 has been properly mounted.
- Verify that all conduit / cable gland entries have been tightened and sealed if necessary.
- Verify that all sensor wiring has been installed correctly.
- Verify that the enclosure has been connected to an earth/ground.
- Verify that the IPES IR3 cover is securely installed
- Disconnect or power down all output devices and alarms to prevent false actuation.

Once you are ready to begin startup, verify that the power supply is connected properly and verify the power supply voltage with the IPES IR3 is disconnected at the source. The IPES IR3 is powered by 24 VDC (18 to 32 VDC voltage range).

After completing the above, the IPES IR3 is ready to be powered on.

Performance Test

After installation is complete, conduct a performance test as follows, to ensure that the detector is functioning properly.

Test Equipment

ESP Safety, Inc.'s ITES Dual-Test Lamp (part number 120-0007) is designed to assist in the functional testing of the detectors without the need to remove the detector from the application. The Test Lamp generates directed modulated radiation with sufficient intensity to signal a flame or fire response to the detector, indicated by a flashing red LED on the IPES-IR3.

Each Test Lamp is supplied pre-assembled with an emission source, housing, batteries, and an Operating Manual.



**ITES Dual-Test Lamp
(Part Number 120-0007)**

Power-On Self-Test

After supplying power to the detector (24VDC +/-8VDC) the unit will perform a self-test procedure

1. When power is applied, the status indicator led lights up for 3 seconds in a solid yellow color. In three seconds, the status led will blink yellow for 7-8 seconds, after this, the self-testing of the device starts (three self-test lamps beneath the cantilevers of the optics window will flash three times).
 - a. The 'Working order' relay (R_WORK on the IPES-IR3 X3 receptacle) will be open (Fault Indication) during portions of the initial self-test cycle.
 - b. The analog +4 to 20mA output will be at 2.0mA indicating the IR 3 is in the power on mode
2. After the self-test, the LED will glow with a solid color depending on the test results: **yellow**-test failed, **green**-the device is operable

IPES-IR3 in Self-Test Mode

After a successful test, the output signals of the IPES-IR3 will be in the following states:

- Actuation (closure of contacts) of 'Fault relay, indicating a 'Working order' /operational condition.
- Indicator led has a solid **green** light, which corresponds to the 'Normal work'/operational mode of the detector as detailed in the next image.
- The +4-20mA analog output will be at (4±0,1) mA (Operational Status)


Fire Detection Test

After installation is complete, conduct a fire detection test to ensure that the detector properly detects a fire condition.

An optional Test Lamp in conjunction with a magnetic Test collar are used to perform the test on the IPES-IR3.



Fig 7-1: Placement of Magnetic Collar and Testing with Test Lamp




Photonic Detector Locations

- Attach the Magnetic Collar with the Magnet placed into the slot on the enclosure. This will put the IPES-IR3 into Fault Mode and the status LED will change from **Green** to **Yellow** indicating a Test function.
- Point the laser beam at the mid-range sensor 4.45 uM IR detector. This will set the IPES-IR3 into fire indication mode. The status indicator will now blink yellow-red indicating *both Fault and Fire conditions*.
- To prevent a false alarm during this test, the Fault relay will be actuated (In an open state) and the Fire relay will remain in a not active state (Open)
- The Analog +4 to 20mA will indicate 8mA for Test Mode
- Once testing is successfully completed, remove magnetic collar to return the IPES-IR3 into operation.

**Dust/
Obstruction Fault
Test**

Simulation of dust or obstruction on optical window of the IPES-IR3 is done by placing a non-transparent material with good reflective properties (white sheet of paper) in front of the optical window of IR channel for 15-20 sec.



If the Dust/obstruction detection function is working properly, the FAULT Relay will activate (Open) and the status LED will alternate YELLOW-GREEN to indicate the fault.

When the obstruction is removed, the status indicator will return to the GREEN-Operational State and the Fault Relay will return to the normal closed state.

8.0 Troubleshooting



The sensor module ("front" half of the detector) contains no user-serviceable components and should never be opened. The terminal compartment is the only part of the enclosure that should be opened by the user in the field.

Troubleshooting Table

If testing reveals a Fault condition or failure to detect a flame, follow the troubleshooting procedures in the table below. The table describes a variety of possible failures and corrective actions.

If the troubleshooting procedures do not correct the problem, contact ESP Safety Inc.

Failure Symptoms	Possible Cause	Corrective Procedure
Red LEDs do not glow.	No power supply.	Detach the base with the cable entry from the IPES-IR3 enclosure and make sure that the terminals are supplied with a voltage of 24±8 VDC.
Fault relay contacts are open; signaling LEDs blink frequently.*	Optical interference (dust)	<p>Clean the IPES-IR3 window with:</p> <ul style="list-style-type: none"> • <i>Commercially available optical lens cleaning pads</i> • <i>Optical Lens Cleaning Solution and optical grade suede chamois</i> • <i>Flushing the surface with Isopropyl Alcohol</i> <p>A clean soft cloth or cotton swab dampened with Isopropyl Alcohol. After wiping the surface with alcohol, wipe it again with a dry cloth in order to remove residual film.</p>
IPES does not react to the test flame.	Optical interference (dust, or contaminated with substances) preventing passage of radiation to the detector.	Wipe the protection windows with a soft cloth wetted with denatured isopropyl alcohol (IPA) and then wipe with a clean dry cloth to remove any residue of dirt.

9.0 Maintenance



Disconnect or power down all output devices and alarms to prevent false actuation.

Maintenance Activities

IPES-IR3 maintenance includes the following activities:

- Visual examination
- Cleaning
- Checking the grounding and explosion-protection systems
- Performance test.

This section describes maintenance activities to be performed once a day or every six months. Automatic testing is also discussed.

Daily Maintenance

Visual Examination

Perform a daily examination of the IPES-IR3, checking for any visible mechanical damage such as dents to the enclosure or a cracked lens. If any damage is noted, immediately pull the detector from service and replace with a new detector.

Every Six Months

Every six months, or as required, perform the following:

Cleaning

Clean the IPES-IR3 every six months (if there is no visible severe contamination) or as required if the signal "Fault" arises; also clean the surface of the detector if it is covered with dust. To clean the detector:

- **Enclosure** - Remove dust from the enclosure with a brush or a soft cloth slightly wetted with denatured isopropyl alcohol (IPA). After wiping the surface with alcohol, wipe again with a clean dry cloth to remove any residual dirt.
- **Protection windows** – Clean with a soft cloth wetted with denatured isopropyl alcohol (IPA). After wiping the surface with alcohol, wipe again with a clean dry cloth to remove any residual dirt.

Grounding and Explosion-Protection Systems

Check to be sure that the joints are sufficiently tight. Thoroughly clean the external grounding wire and apply anti-seize lubricant (supplied by the manufacturer) on the critical joints as referenced in Appendix B (Drawing 80031-001).

Perform this test on all detectors in the system.

1. Apply power to the detector. After 1 to 5 seconds, the output current will increase to 4 mA, and the indicating LEDs will start blinking.
2. If it is necessary to isolate the detector fire relay from the alarm system, apply the magnetic collar over the enclosure as shown in Figure 7-1. Placing the collar over the enclosure as shown allows the fire relay contacts to remain in the non-alarm state during testing.
3. Perform the test with the ITES Test Lamp as follows:
 - Attach the Magnetic Collar with the Magnet placed into the slot on the enclosure. This will put the IPES-IR3 into Fault Mode and the status LED will change from Green to Yellow indicating a Test function.
 - Point the laser beam at the mid-range sensor 4.45 μ M IR detector. This will set the IPES-IR3 into fire indication mode. The status indicator will now blink yellow-red indicating *both Fault and Fire conditions*.
 - To prevent a false alarm during this test, the Fault relay will be actuated (In an open state) and the Fire relay will remain in a not active state (Open)
 - The Analog +4 to 20mA will indicate 8mA for Test Mode

If any detector fails this test, refer to Section 8.0, Troubleshooting.

4. Once testing is complete, remove the magnetic collar before reconnecting the detector to the fire-alarm or burglar-fire alarm system.

NOTES:

- Always make sure that the ITES Test Lamp has fresh batteries.
- Keep the Test Lamp lens free from dust, dirt, and moisture. If necessary, clean the lens with a soft wool or cotton cloth.

Automatic Testing

If the lens becomes dirty or coated, a change in radiation transmissibility could reduce the detector's sensitivity. To safeguard against this, the IPES-IR3 continuously tests the lens for optical clarity and sends a Fault alarm when the radiation transmissibility reaches a critical threshold.

In addition, the sensors are routinely tested every 25 to 45 minutes by use of internal test lamps. If the IPES-IR3 does not pass the self-test, a Fault alarm is sent. This routine test does not require the use of an external ITES Test Lamp.

10.0 Transportation and Storage

Transportation	When shipped in the factory-supplied carton, the model IPES-IR3 can be shipped via any method of transportation from the manufacturer's site to any destination regardless of distance.
Storage	Until use, store the detector in the manufacturer's original carton. The storage facility should be free of dust, acid and alkaline vapors, corrosive gases and other harmful substances.

11.0 Warranties

ESP Safety, Inc. ("ESP") warrants the IPES-IR3 Flame Detector to be free from defects in material and workmanship under normal use and service for a period of five (5) years, beginning on the date of shipment to the buyer. This warranty extends only to the sale of new and unused products to the original buyer. ESP's warranty obligation is limited, at ESP's option, to refund of the purchase price, repair, or replacement of a defective product or a component thereof, to the extent that the product is properly returned to ESP within the warranty period.

This warranty does not include:

- a) fuses, disposable batteries or the routine replacement of parts due to the normal wear and tear of the product arising from use;
- b) any product or component which in ESP's opinion, has been misused, altered, abused, tampered with, improperly maintained or used, neglected or otherwise damaged by accident or abnormal conditions of operation, handling or use, or to have deteriorated due to aging of any component made of rubber or any other elastomer; or
- c) any damage or defect attributable to repair of the product by any person other than an authorized dealer, or the installation of unapproved parts on the product.

The obligations set forth in this warranty are conditional on:

- a) proper storage, installation, calibration, use, maintenance and compliance with the product manual instructions and any other applicable recommendations of ESP;
- b) the buyer promptly notifying ESP of any defect and, if required, promptly making the product available for correction. No goods shall be returned to ESP until receipt by buyer of shipping instructions from ESP. A return authorization number must be obtained from ESP prior to shipment; and
- c) all warranty returns being shipped directly to ESP Safety, Inc.;
- d) the right of ESP to require that the buyer provide proof of purchase such as the original invoice, bill of sale or packing slip to establish that the product is within the warranty period.

THE BUYER AGREES THAT THIS WARRANTY IS THE BUYER'S SOLE AND EXCLUSIVE REMEDY AND IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. ESP SHALL NOT BE LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES. ESP WILL NOT BE LIABLE FOR LOSS OR DAMAGE OF ANY KIND CONNECTED TO THE USE OF ITS PRODUCTS OR FAILURE OF ITS PRODUCTS TO FUNCTION OR OPERATE PROPERLY. IN NO EVENT SHALL ESP'S LIABILITY HEREUNDER EXCEED THE PURCHASE PRICE ACTUALLY PAID BY THE BUYER FOR THE PRODUCT.

To the extent any provision of this warranty is held invalid or unenforceable by a court of competent jurisdiction, such holding will not affect the validity or enforceability of any other provision.

Expected Service Life of Unit	The average expected life of the IPES-IR3 is not less than 10 years.
--------------------------------------	--

12.0 Repair and Return

Field Repair

The IPES-IR3 detector is not intended to be repaired in the field. If a problem should develop, refer to Section 8.0 Troubleshooting of this manual. If it is determined that the problem is caused by a manufacturing defect, please return the device to the factory for repair or replacement.

Return Material Authorization (RMA) Number

Contact ESP Safety Inc. at +1-408-886-9746 to obtain a Return Material Authorization (RMA) number. Please provide the following information during your call:

- Your Company Name
- Product Type
- Serial Number
- Date of Shipment
- Brief explanation of malfunction

Pack the unit properly to ensure that no shipping damage occurs and ship to:

ESP Safety, Inc.
555 North First Street
San Jose, CA 95112 USA

Write the RMA number on the front of the shipping carton

ESP Safety, Inc. recommends that an inventory of spare detectors be kept on hand to enable rapid field replacement and minimize downtime.

13.0 Parts Ordering Information

The following items for the IPES-IR3 may be ordered:

- IPES Mounting Hardware, part number 120-0048
- ITES Test Lamp, part number 120-0007
- Magnetic collar, part number 120-0006




Order from:

ESP Safety Inc.
555 North First Street
San Jose, CA 95112 USA
Ph: 408-886-9746
Fax: 408-886-9757

Please note that shipping charges will be added to your order.

14.0 Certifications

The IPES-IR3 meets the following certifications:

<p>FM (U.S. & Canada)</p> <p>Hazardous Locations</p> <p>Zone Locations</p>	 <p>Class I, Division 1, Groups B, C & D, T4, Ta = -40°C to +85°C (-40°F to +185°F) IP66</p> <p>Class I, Zone 1, AEx d IIC, T4, Gb</p> <ol style="list-style-type: none"> 1. ISO Class 12.9, M5 X 20 socket-head cap screws (Yield Stress 1100 MPa) shall be used to replace the cover fasteners. 2. ISO Class 12.9, M5 X 25 socket-head cap screws (Yield Stress 1100 MPa) shall be used to replace the base fasteners.
<p>Fire Protection Equipment</p>	<p>Approval Standards: FM3260 (2000); FM3600 (1998); FM3615 (2006); ANSI/ISA 60079-0 (2009); ANSI/ISA 60079-1 (2009); CAN/CSA-C22.2 No. 60079-0 (2007); CAN/CSA-C22.2 No. 60079-1 (2007)</p> <p>Supporting Standards: ANSI/FM3260 (2004); ANSI/NFPA 72 (2002); ULC/ORD – C386 (1990); CAN/ULC – S529 (2002); CSA C22.2 No. 0.5 (reaffirmed 1999); C22.2 No. 32 (reaffirmed 2003); ANSI/IEC 60529 (2004); CSA-C22.2 No. 60259 (2005)</p>
<p>ABS</p>	 <p>Class I, Division 1, Groups B, C & D, T4 Ta = -40°C to +85°C (-40°F to +185°F) IP66</p>
<p>ATEX/CE</p>	 <p>Flameproof “d”</p> <p>Ex d IIC T4 Gb Ta = -40°F to +185°F (-40°C to +85°C)</p> <p>Supporting Standards: EN 60079-0:2009; EN 60079-1:2007</p> <p>ATEX Certificate Number: FM11ATEX0045X</p> <p>Specific Conditions of Use:</p> <ol style="list-style-type: none"> 1. ISO Class A2-70, M5 X 16 socket-head cap screws (Yield Stress 450 MPa) shall be used to replace the cover fasteners. 2. ISO Class A2-70, M5 X 16 socket-head cap screws (Yield Stress 450 MPa) shall be used to replace the base fasteners. 3. Consult the manufacturer if dimensional information on the flameproof joints is necessary. <p>Certificate of Conformity: CE Mark for EMC (TUV)</p> <p>CE Mark for ATEX</p> <p>IP66</p>

IEC/IECEX	Flameproof “d” Ex d IIC T4 Gb Ta = -40°F to +185°F (-40°C to +85°C) Supporting Standards: IEC 60079-0:2007; IEC 60079-1:2007 IECEX Certificate Number: IECEX FMG 11.0012X Specific Conditions of Use: <ol style="list-style-type: none">1. ISO Class A2-70, M5 X 16 socket-head cap screws (Yield Stress 450 MPa) shall be used to replace the cover fasteners.2. ISO Class A2-70, M5 X 16 socket-head cap screws (Yield Stress 450 MPa) shall be used to replace the base fasteners.3. Consult the manufacturer if dimensional information on the flameproof joints is necessary.
Ingress Protection	IP66 = Dust Tight, Powerful Jetting

Appendix A: IPES-IR3 Explosion Protection Means

Feature	Protection Means
<i>Enclosure of Current Carrying Parts</i>	The casing includes spigot joints with controlled gaps to meet explosion-proof requirements for installation in Class I, Division I, Group B, C and D, and T4 locations.
<i>Case Mechanical Strength</i>	The high mechanical strength of the case is able to withstand high explosive pressures without rupture or failures of mechanical parts. The case design is in accordance with FM 3600 and FM 3615.
<i>Manufacturing Control Of Casing</i>	Refer to Appendix B for manufacturing details. Important parameters include: <ul style="list-style-type: none"> • Maximum width and minimum length of spigot joints • Surface roughness of the joined parts • The number of complete intact threads at the conduit entry point
<i>Ignition Temperature</i>	The ignition temperature of the surrounding environment is limited by the outside surface temperature of the housing, which does not exceed 275°F (135°C).
<i>Securing of Bolts, Joints and Grounding</i>	Spring washers, lock washers, and lock nuts maintain the integrity of the bolted connections by preventing loosening of the bolts.
<i>Joined Parts Protection</i>	Anti-seize lubricant is applied on the critical joints as described on Appendix B.
<i>Casing Ingress Protection</i>	The design of the casing is protection class IP 66 in accordance with IEC 60529-004.
<i>Sealing Cables at Conduit Entry</i>	Use approved hazardous location sealed conduit fittings. For outdoor installations, ensure sealing meets IP66 requirements.

Appendix B: IPES-IR3 Installation




Figure A-2: Installation




Figure A-2: Installation

Appendix C: IPES Digital Communications Protocol**IPES Commands**

In addition to supporting analog signals (current loop and relays), IPES-IR3 flame detectors are also capable of digital communications with remote consoles. IPES-IR3 detectors use a standard RS-485 interface with a Modbus RTU protocol layer defining the transactions between the IPES-IR3 and the console. Refer to the document "MODBUS APPLICATION PROTOCOL SPECIFICATION v1.1bx" available online at www.modbus.org for complete details of the Modbus protocol.

**Setting Address/
Baud Rate
Command**

The factory default Modbus address for the IPES-IR3 is 247. The factory default baud rate for each detector is 9600.

The following 8-byte Modbus command must be sent to the IPES-IR3 in order for the Modbus address and baud rate to be changed:

Set address/baud rate command	
Byte	Description
0	Current Modbus address (247 if IPES-IR3 set to factory default)
1	6 (Modbus function code for writing to the device)
2	0
3	0
4	New Modbus address (must be in the range 1 to 247)
5	New baud rate (must be one of the following values): 1 – 1200 baud 2 – 2400 baud 4 – 4800 baud 8 – 9600 baud 16 – 19200 baud
6	Low byte of 16-bit CRC
7	High byte of 16-bit CRC



The Modbus address and baud rate are stored in non-volatile memory with a write endurance of 10000 erase-write cycles. Repeated transmission of the set address/baud rate command to the IPES-IR3 detector can potentially degrade the memory beyond its ability to retain the data being written to it. The address and baud rate should be changed only when necessary to connect the IPES-IR3 detector to a remote console.

The IPES-IR3 will respond to the host by transmitting an identical packet to the host at the original baud that was used to receive the command. After the response has been transmitted, the IPES-IR3 will change its Modbus address and baud rate to the ones specified in the command. At that point, the remote console must change its baud rate in order to communicate further with the detector. The new Modbus address and baud rate are stored in non-volatile memory and these parameters will be retained through power cycles.


Poll Status Command

The following 8-byte Modbus command may be sent in order to poll the status of the IPES-IR3:

8-byte Modbus command	
Byte	Description
0	Current Modbus address (247 if IPES-IR3 set to factory default.
1	4 (Modbus function code for reading from the device)
2	0
3	1
4	0
5	1
6	Low byte of 16-bit CRC
7	High byte of 16-bit CRC

The IPES-IR3 responds with a 7-byte packet with the following format:

7 byte Poll Status Command	
Byte	Description
0	Current Modbus address
1	4 (Modbus function code for reading from the device)
2	2
3	Status: Bit 0: 1 = fast detection, 0 = slow detection Bit 1: 1 = high sensitivity, 0 = medium sensitivity Bit 2: 1 = latching on, 0 = latching off Bit 3: 1 = fire relay enable, 0 = fire relay disable Bit 4: 1 = fault relay enable, 0 = fault relay disable Bit 5: 1 = heater enable, 0 = heater disable Bit 6: 1 = very high sensitivity enable, 0 = very high sensitivity disable Bit7: not used
4	Detector status Bit 0: 1 = fire detected, 0 = no fire detected Bit 1: 1 = hardware fault, 0 = no hardware fault Bit 2: 1 = dust fault, 0 = no dust fault Bits 3-7: not used.
5	Low byte of 16-bit CRC
6	High byte of 16-bit CRC



Sending any commands other than the ones specified is not permitted.